

# Certificate



Aktiengesellschaft

No. Z2887a-12-E

## Customer:

LEONI Kerpen GmbH  
Zweifaller Str. 275 - 287  
D-52224 Stolberg

## Test sample(s):

- Cu- Trunk:  
**LEONI Kerpen MegaLine F10-115 S/F**  
mounted with:  
**LEONI Kerpen MegaLine Connect 45 – Kat.6<sub>A</sub>**  
Part No.: LKD9A0612830000K; LKD9A0612030000VK;  
LKD9A0612840000K; LKD9A0612040000VK
- Patchcord:  
**LEONI Kerpen MegaLine Patch 6EA**  
Part No.: LKD9A0211350000
- CP- Cable:  
**LEONI Kerpen MegaLine CP-Cable**  
Part No.: LKD9A0233430000K, LDK9A0233530000VK

## Applied standard(s):

- ISO/IEC 11801 AMD 1 (2008-04)

## Results:

Up to a bandwidth of **500 MHz** the sample meets the **Class E<sub>A</sub>** limits of the specified standards and regulations.

## 4 Connector Channel, Class E<sub>A</sub>

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2887a-12-E**, dated **May 23<sup>th</sup>, 2012** and shall only be applicable in conjunction with the test report.

Bexbach, May 23<sup>th</sup>, 2012

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
Email: info@ghmt.de