

# Certificate



Aktiengesellschaft

No. z2577d-11-E

## Customer:

LEONI Kerpen GmbH  
Zweifaller Str. 275 – 287  
D-52224 Stolberg

## Test sample(s):

Modular Jack:  
**MegaLine Connect45 Cat.6A**  
Part No.: 9A501020; 9A501021;  
9A502020; 9A502021;  
9A505020;

## Applied standard(s):

- ANSI/TIA-568-B.2-10 (2008-03)
- TIA/EIA-568-C.2 (2009-08)

## Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6A** limits of the specified standards and regulations.

## Modular Jack, Category 6A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the components are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2577d-11-E**, from **June 21<sup>st</sup>, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, June 21<sup>st</sup>, 2011

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
Email: info@ghmt.de