

Certificate



Aktiengesellschaft

No. z2577c-11-E

Customer:

LEONI Kerpen GmbH
Zweifaller Str. 275 – 287
D-52224 Stolberg

Test sample(s):

Modular Jack:
MegaLine Connect45 Cat.6_A
Part No.: 9A501010; 9A501011;
9A502010; 9A502011;
9A505010;
9A503214; 9A503215

Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- IEC 60603-7-51 (2010-03)

Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6_A** limits of the specified standards and regulations.

Modular Jack, Category 6_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the components are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P2577c-11-E, from June 21st, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, June 21st, 2011

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de